

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3550-0257:105 Page 1 of 1

**CATEGORY:** Door Closers/Holders

**LISTEE:** Yale, 1902 Airport Rd., Monroe, NC 28110  
Contact: \*Jeff Trull (704) 283-2101

**DESIGN:** Model 4240 series. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as door holders/closers. These units may be interconnected to other approved combination door closers/holders, to separately listed detector-thermostats, or to Model MPD-I smoke detector (CSFM Listing No. 7256-257:107). When interconnected to any detector, a separately listed compatible control unit must also be used.

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager